## CERTIFICATE OF COMPLIANCE

Certificate Number 20161111-EX5002
Report Reference EX5002-20160709A
Issue Date 2016-November-11

Issued to: VIKING CORP

210 INDUSTRIAL PARK DR HASTINGS MI 49058-9706

This is to certify that PROPORTIONERS, FOAM CONCENTRATE

representative samples of See addendum page

Have been investigated by UL in accordance with the

Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 162, Standard for Safety for Foam Equipment and

Liquid Concentrates.


Additional Information: See the UL Online Certifications Directory at

www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.





UL LLC





## CERTIFICATE OF COMPLIANCE

Report Reference EX5002
Issue Date 2016-No

20161111-EX5002 EX5002-20160709A 2016-November-11

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model VRC 2, 2-1/2, 3, 4, 6 and 8 in. ratio flow controllers.

Following are equivalent length valves for the controllers based on a roughness factor of 130 and schedule 40 steel pipe.

Controller Size In.	Equivalent Length Ft
2	42.9
2-1/2	38.0
3	27.6
4	32.6
6	86.8
8	113.6

## IN-LINE BALANCED PRESSURE INVESTIGATED TO UL 162

Model VLF assemblies incorporate a positive displacement pump or bladder tank and 3, 4, 6 and 8 in. controllers.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <a href="http://ul.com/aboutul/locations/">http://ul.com/aboutul/locations/</a>

